

Killarney Community Nursing Unit



Registration details:

Centre Name: Killarney Community Nursing Unit

Centre ID: 9292

Centre type: Dhaoine Scothaosta

Status: Registered

Address: Upper Lewis Road, Ballydribbeen, Killarney, V93 C3XW

County: Kerry

Phone: TBC

Maximum Occupancy: 130

Person(s) in charge: Maire Flynn

Person in charge phone number: 064 663 1018

Management contacts:

Susanne O'Sullivan - 087 122 0582, Niamh Lordan - 087 342 0414

Registered Provider: Health Service Executive

Registration Number: REG-0046660

Registration Date: 15-06-2026

Registered Provider Address: Oak House, Millennium Park, Naas, W91 KDC2, Kildare

Registered Provider Phone: 045 880 400

Expiry: 14-06-2029

Registration Conditions:

Condition 1

Subject to any prohibitions or restrictions contained in any other condition(s), the designated centre shall be operated at all times in accordance with the Statement of Purpose within the footprint of the designated centre on the floor plan received 29th May 2026. The registered provider shall only provide for the specific care and support needs, and services, within the facilities as set out the Statement of Purpose, as agreed with the Chief Inspector at the time of registration. Any changes to the specific care and support needs and services provided must be agreed in advance with the Chief Inspector.

Condition 2

Only persons aged 18 years or older shall be accommodated at the designated centre at any time.

Condition 3

The maximum number of persons that may be accommodated at the designated centre is: 130

Condition 4

In order to ensure that residents accommodated in Killarney Community Nursing Unit are protected from the risk of fire, the Health Service Executive will by 31 October 2026 install additional emergency lighting to provide illuminated pathways for escape to a final place of safety both internally and externally.

Condition 5

In order to ensure that residents living in Killarney Community Nursing Unit are protected from the risk of infection and are accommodated in a building that is appropriate to their needs, the Health Service Executive will

- By the 30 August 2026 complete the installation of swing free devices, which are connected to the fire alarm system, to each door set leading into residents' toilets and bathroom spaces
- By the 30 October 2026 complete the installation of a local alarm system connected to Break Glass Units adjacent to the escape ladder exit points to the first floor stairway
- complete the installation of a powder coated metal ceiling to all waste hold rooms
- ensure that the washing machines required for onsite laundering of mops and other cleaning materials are fit for purpose and in line with best practice

In the interim of achieving compliance with this condition the HSE is required to ensure that there are appropriate mitigation measures in place to protect residents living in Killarney Community Nursing Unit.