

# Aperee Living Conna



## Registration details:

**Centre Name:** Aperee Living Conna

---

**Centre ID:** 4447

---

**Centre type:** Older Person's

---

**Status:** Registered

---

**Address:** Conna, Mallow, P51 W110

---

**County:** Cork

---

**Phone:** 058 59 876

---

**Maximum Occupancy:** 50

---

**Person(s) in charge:** Resmi Rajan

---

**Person in charge phone number:** 052 618 2000

---

### Management contacts:

Maura O'Sullivan - 086 851 6523

---

**Registered Provider:** Conna Care Home Ltd

---

**Registration Number:** REG-0035310

---

**Registration Date:** 04-01-2022

---

**Registered Provider Address:** 46 St Mary's Road, Midleton, P25 KX56, Cork

---

**Registered Provider Phone:** 021 462 1094

---

**CRO Registration Number:** 548745

---

**Expiry:** 03-01-2025

---

### Registration Conditions:

#### Condition 1

Subject to any prohibitions or restrictions contained in any other condition(s), the designated centre shall be operated at all times in accordance with the Statement of Purpose within the footprint of the designated centre on the floor plan dated 15/09/2021. The registered provider shall only provide for the specific care and support needs, and services, within the facilities as set out the Statement of Purpose, as agreed with the Chief Inspector at the time of registration. Any changes to the specific care and support needs and services provided must be agreed in advance with the Chief Inspector.

#### Condition 2

Only persons aged 18 years or older shall be accommodated at the designated centre at any time.

#### Condition 3

The maximum number of persons that may be accommodated at the designated centre is: 50.

Condition 4 By the 31 October 2023 the registered provider shall ensure that the following works to improve fire safety are completed

- Upgrade of ceilings of bedrooms to fire rated ceilings
- Upgrade of external escape routes to rear of building
- Servicing and/or replacement of inadequate fire doorsets and internal screens
- Upgrade of laundry room fire rating to area added to room
- Provision of passive fire protection to all ventilation outlets passing through fire rated construction